

MANCHESTER PUBLIC SCHOOLS  
45 NORTH SCHOOL STREET  
MANCHESTER, CT 06042

**RFP #016-002**  
**ROBERTSON ELEMENTARY SCHOOL**  
**PORTABLE CLASSROOM DEMOLITION**

**ADDENDUM #2**  
**July 28, 2015**

1. The spec makes reference to gymnasium floor refinishing on page 14, please elaborate?  
*The posted RFP does not reference the gymnasium floor. Please review the document found here:*  
[http://mpspride.org/uploaded/District\\_Office/Departments/Business/016-002\\_Robertson\\_Portables\\_Demolition.pdf](http://mpspride.org/uploaded/District_Office/Departments/Business/016-002_Robertson_Portables_Demolition.pdf)
2. Page 14 refers to all Freon being removed by “others “ prior to starting , page 19 request a statement of refrigeration recovery and technician licensed , please advise if the contractor removes the Freon.  
*The reference on page 14 to Freon being removed by others is in error. We will require the proposer to remove the Freon and certify that it was done properly.*
3. Will there be a hazard assessment done outlining the presence of asbestos or not, and any other hazardous material present; ie bulbs, ballast mercury switches, etc.?  
*There is no asbestos in the building. No mercury containing materials have been found in the building. Hazardous materials that will remain after the owner reserve materials/items have been removed will be limited to lamps and ballasts.*